


CIVIL SURGEON OFFICE, TARN TARAN

No.:CSTT 41

Dated: 30/5/2023

TO WHOM IT MAY CONCERN

This is to certify that we have inspected **Saint Soldier Convent School, Poonia Road, Gharyala, Distt. Tarn Taran.** After inspecting their Toilets, Kitchen, Canteen and other Rooms, we hereby certify that their Cleanliness and Sanitation are good. Their water is Potable through RO system as per of Rural Water Supply and Sanitation Department. This certificate is valid for one year from the date of issue. No Health Hazard is seen in the premises of the school.


District Epidemiologist
TARN TARAN


DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1t@gmail.com

To,

SAINT SOLDIER SEN. SEC. SCHOOL
Gharyala

No.: DWTLTT/2324/00068 Dated : 02/06/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 012 Dated: 01/06/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 01/06/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory, Tarn
Taran

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1t@gmail.com

TEST REPORT						
Name & Address of Customer : SAINT SOLDIER SEN. SEC. SCHOOL Gharyala			Customer Reference No.		No : 012 Dated : 01/06/2023	
			Sample Submitted by		Charanjit Singh	
			Date of Sample Receipt		01/06/2023	
			Analysis Starting Date		01/06/2023	
			Analysis completion Date		02/06/2023	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC103872300000144F		Sample Type :		Water	
Test Report No.:	DWTLTT/2324/00068		Date of Issue :		02/06/2023	
Registration no.:	DWTLTT/REG2324/00093		Condition of Sample :		Unsealed	
Collection Point:	Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		Poonia Road / 700 ft	
Village :	Ghariaala		Habitation :		Ghariaala	
Block:	Valtoha		District :		Tarn Taran	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.00	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	270	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.01	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	240	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	200	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	44.88	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	21.38	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	11.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%



Mr. Pankaj Kumar
Technical Manager
Authorized Signatory
For, District Water Testing Laboratory, Tarn Taran

----- End of the Test Report -----